CERTIFICATE

Certificate number: 2603715 (2)

Issued 25/03/2026
Expires 11/03/2031

Kiwa Regulation 4(KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 (issue 7) – Regulation 4(1)(a)
Model number(s) – see Appendix

iMist Holdings Limited.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)(a) of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Replication of this certificate is allowed in its entirety.
Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.
See https://www.kiwa.com/gb/en-gb/about-kiwa/water-products/ or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
iMist Holdings Limited
293 National Avenue
Hull
HU5 4JB
United Kingdom

KUKreg4

The following products belong to this certificate

PRODUCT DESCRIPTION iMist Y Type Model STS12 inline strainer with a stainless-steel body and filter mesh. ATS3 – Without Production Surveillance.
MODEL(S) 430.
SIZE: 3/8” NPT (M).
SCOPE: Manufacturer recommended maximum working pressure 16 Bar & maximum operating temperature 100°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C.
MARKING iMist, P/N STS, and technical information on body.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes